



केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT FOREST & CLIMATE CHANGE GOVT OF INDIA

By Speed – Post

F.No.B-31011/BMW (27.10)/2023/WMD-1/

July 24, 2023

To

Shri Siddhant Rai Sethi,
876, Dr. Mukherjee Nagar, Delhi,
Near Batra Cinema, Pin:110009

Sub: Information under Right to information Act, 2005- reg.

Ref; CPCBD/R/E/23/00605 dt. 19.07.2023

Sir,

This has reference to your above RTI application dated 19.07.2023 seeking information regarding requirement of separate installation of ETP/STP in HCFs of NCT, Delhi if they already having connection to public sewer which leads to terminal sewage plant. In this regard, it is to inform that as per the Bio-Medical Waste Management Rules, 2016 and amendments thereof, bedded HCFs are required to install ETP plant, if wastewater generated from HCFs is not connected with City's/Town's public sewerage network leading to terminal STP. In case the waste effluent is connected with public sewer which leads to terminal STP, the HCFs do not required to install separate/individual ETP.

Further, non-bedded HCFs are required to only dispose infectious liquid wastes only after treatment by disinfection as per Schedule –II (6) of the BMWM Rules, 2016 and need not to install separate ETP or STP.

Yours faithfully,

(V. P. Yadav)
CPIO

Waste Management Division -I

‘परिवेश भवन’ पर्वी अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, Delhi-110032